



- Notes:
1. Coated metal or uPVC 'Z' flashing minimum 15° slope. Flashing tape upstand to building wrap.
  2. This detail is required at the second storey joist level. Refer E2/AS1 Clause 9.1.9.4



Title: **Drained Mid-floor Joint Detail**

Date: October 2013

Detail No. SP 24-0

This drawing must be read in conjunction with the Superpol Cladding Design Guide