



NOTE

For double layer lining systems, the minimum depth of approved fire-rated and acoustic sealant shall be 20mm

Supercrete™

Title:

**A.W.S. - Type 2 and 3 Walls
Fire Rated Control Joint**

Date: December 2013

Scale: N.T.S.

Detail No. 10.4.1

This drawing must be read in conjunction with the Supercrete Acoustic Wall Systems Design Guide